



COMBUSTIBLE MATERIALS IN FACILITIES

Context

Under the B.C. Fire Code, (Division B, Part 2, Section 2.10-3) combustible materials are restricted to 20% of wall area in classrooms and corridors (see attached Combustible Material Chart).


All combustible materials in schools shall meet the Fire Code requirements.

The link below to the government website provides direction on combustible guidelines.


<https://www2.gov.bc.ca/gov/content/safety/emergency-preparedness-response-recovery/fire-safety/guidelines-bulletins-position-papers/guidelines/decorations-in-school-hallways>

Combustible Material Chart

EXAMPLES OF DISPLAY AREAS IN SCHOOL CORRIDORS



WALL AREA = 71 SQUARE METER
SHADED AREA EQUALS 20%



NOT TO SCALE

Relevant Board Policy: N/A
 Developed by: Director of Operations
 Date Agreed: September 1, 2003
 Date Amended: February 8, 2019
 Related Documents: